



TYPE APPROVAL CERTIFICATE

No.
ELE086320XG/006

This is to certify that the product below is found to be in compliance with the applicable requirement of the RINA type approval system.

<i>Description</i>	Differential pressure switch
<i>Type</i>	MP 54, MP 55
<i>Applicant</i>	DANFOSS A/S Nordborgvej 81 DK-6430 Nordborg (office E14-S1) DENMARK
<i>Manufacturer</i>	Danfoss Poland Sp. Z O.O.
<i>Place of manufacture</i>	UL. Chrzanowska 5, PL-05-825 Grodzisk Mazowiecki POLAND
<i>Reference standards</i>	Rules for the Classification of Ships - Part C - Machinery, Systems and fire protection - Ch.3, Sect.6, Tab.1.

Issued in **HAMBURG** on **July 15, 2020**. *This Certificate is valid until* **July 14, 2025**



**RINA Services S.p.A.
Giuseppe Russo**

This certificate consists of this page and 1 enclosure

TYPE APPROVAL CERTIFICATE

No.

ELE086320XG/006

Enclosure - Page 1 of 1

MP 54, MP 55

Differential pressure switch type MP 55

Type	Range adjustment	Differential (psi)	relay time delay
MP 54	LP side 29 inch Hg to 175 psi	6 to 9	45 to 120 s
MP 55		4.3 to 64	

Additional Plant of Manufacturing

Danfoss Industries Pvt.
A-19/2 SIPCOT Industrial Growth Center
Oragadam, Tamil nadu
602105 India

Reference Documents

Danfoss differential pressure controls / lube oil protection controls n° RK.0X.E1.22

This certificate replace the previous certificate ELE004815/001.

HAMBURG July 15, 2020

